

CITY OF KENOSHA, WISCONSIN

ADDENDUM #1

PROPOSAL NOTICE #02-20 - REQUEST FOR PROPOSAL TO REMOVE AND DISPOSE OF ASBESTOS CONTAINING MATERIAL, UNIVERSAL WASTE AND LEAD BASED PAINT AT 702 58TH STREET

ADDENDUM ISSUED: Thursday, February 27, 2020

Please be advised that:

1. Any wooden sub floors ingrained with black mastic may be removed when the mastic and tile are removed.
2. Any lead based paint identified in the interior of the building must be removed and not just the peeling and flaking lead based paint.
3. All proposals must be submitted using the revised proposal form (attached).
4. The awarded contractor will be given at least 60 days to complete the work and not 30 days as listed in the sample contract attached to the Request for Proposal.
5. Questions and/or requests for additional inspections of the property can be directed to Zohrab Khaligian at 262-653-4041 or zkhaligian@kenosha.org. Only contractors who attended the mandatory inspection on Tuesday, February 25, 2020 may schedule an additional inspection.
6. There are no other changes, clarifications or additions pursuant to these solicitations. Proposal Opening is still Tuesday, March 10, 2020 at 2:30pm

